



Field test of hydrogen in the natural gas grid

EFP05 J.nr. 033001/33031-0053

**Project Report
August 2010**

RAPPORT

Field test of hydrogen in the natural gas grid

EFP05 J.nr. 033001/33031-0053

Henrik Iskov

Title : Field test of hydrogen in the natural gas grid, EFP05 J.nr. 033001/33031-0053

Report Category : Project Report

Author : Henrik Iskov

Date of issue : 13 August 2010

Copyright : Danish Gas Technology Centre

File Number : 727-73; h:\727\73 naturgasnet m h2 fase ii\slutrapportering\finalreportefp05.doc

Project Name : Naturgasnettets anvendelighed til ren brintdistribution, fase II

ISBN : 978-87-7795-334-7

Table of Contents**Page**

1	Summary	3
1.1	Summary in English	3
1.1.1	Distribution grid - polymer pipes	3
1.1.2	Transmission grid - steel pipes	3
1.2	Summary in Danish	4
1.2.1	Distributionsnet - plastrør	4
1.2.2	Transmissionsnet - stålrør	5
2	Introduction and objectives	6
3	Polymer pipe test and analysis	7
3.1	Test set-up	7
3.2	Samples used in the analysis	8
3.3	The analytical program	8
3.4	Results	9
3.4.1	General findings	9
3.4.2	Determination of changes in slow crack growth	9
3.4.3	PE 80 pipes	9
3.4.4	PE 100 pipes	10
3.4.5	Determination of structural changes	11
3.4.6	Determination of oxidative power - consumption of antioxidants	12
3.4.7	Determination of changes in tensile properties	13
3.5	Polymer testing conclusion	14
4	X70 steel natural gas transmission pipeline test and analysis	16
4.1	Introduction and objectives	16
4.1.1	The object of the steel pipe test	16
4.2	Analysis	18
4.3	Conclusion of steel tests	19
5	References	20

Appendices

Appendix 1: Borealis Innovation Project Report

Appendix 2: FORCE final report

Abbreviations used

SCG	=	Slow crack growth
OIT	=	Oxygen Induction Time
ESCR	=	Environmental Stress Cracking
CTL	=	Constant Tensile Load, name of test method.
PE 80	=	Polyethylene pipe material fulfilling classification of MRS 8,0 MPa
PE 100	=	Polyethylene pipe material fulfilling classification of MRS 10,0 MPa
MRS	=	Minimum required strength at 50 years
DGC	=	Danish Gas Technology Centre
FTIR	=	Fourier Transform Infra Red analysis
MFR	=	Melt Flow Rate
FRR	=	Flow Rate Ratio
ISO	=	International Organisation for Standardisation
MPI	=	Magnetic Particle Inspection
CH ₄	=	Danish natural gas

1 Summary

1.1 Summary in English

In order to prepare for a future use of hydrogen as a fuel gas it became evident that very little information existed regarding the compatibility between long-term exposure and transportation of hydrogen in natural gas pipelines. A program was therefore set to study the transportation in a small-scale pilot grid at the research centre in Hørsholm, Denmark.

The test program included steel pipes from the Danish gas transmission grid and polymer pipes from the Danish and Swedish gas distribution grid.

1.1.1 Distribution grid - polymer pipes

The test of polymer pipes was devised so that samples of all test pipes were cut out of the grid each year and analysis performed on these pipe samples; in this way any form of influence on the integrity of the polyethylene pipe would be detected.

The analytical program for polymer was devised in order to detect any influence on the additivation of the polyethylene as this has an influence on oxidative resistance, as well as checking already encountered possible degradation caused by extrusion of the material. Further tools as rheology and melt flow rate were used for detecting any structural changes on the material. On the mechanical property side the tensile strength and modulus were followed as well as the most important property for the pipe line, namely slow crack growth.

The results of the polymer pipe tests show no degradations of any kind related to the continuous hydrogen exposure for more than 4 years. This is a strong indication of the compatibility to hydrogen of the tested polymer materials PE 80 and PE 100.

1.1.2 Transmission grid - steel pipes

The object of the steel pipe test was to see the effect on fatigue life of existing natural gas transmission lines with hydrogen replacing the natural gas.

Full-scale dynamic tests were performed using randomly selected cut-out API 5L X70 pipe sections with a diameter of 20 inches and a wall thickness of 7 millimetres from the Danish natural gas transmission system. The pipe sections contained field girth weld made during the installation of the pipe line in the early 1980's.

These pipe sections were exposed to pressure variations equal to twice the maximum daily swing in the Danish gas transmission grid. The number of pressure variations equals 80 years of operation. The results of analysing the weldings afterwards show no growths in defects. If the pipe sections available for the test are representative for the Danish gas transmission grid, the test result indicates that hydrogen can be compatible with the pressure swing in the gas transmission grid.

1.2 Summary in Danish

Litteraturundersøgelser /1/ viste, at der kun fandtes ganske lidt information om det eksisterende naturgasnets anvendelighed til transport af brint. Derfor igangsatte man et projekt, der skulle undersøge brinttransport i naturgasnettet i et forsøgsanlæg hos Dansk Gasteknisk Center i Hørsholm. Projektet omfattede stålør fra det danske gastransmissionsnet og plastrør fra det danske og svenske gasdistributionsnet.

1.2.1 Distributionsnet - plastrør

Testen af plastrørene blev udformet således, at der en gang årligt blev udsåret en rørstump af samtlige testør. Herefter gennemførtes en omfattende analyse for at afdække, hvorvidt plastrørene blev degraderet af brinten.

Analyseprogrammet, der blev opstillet til testen af plastrørene, var udformet med henblik på at detektere en eventuel indflydelse fra brint på additivstofferne i plasten, da dette igen vil påvirke modstandsdygtigheden over for oxidering (hvilket i afgørende grad påvirker fx svejsbarheden af rørene). Analyseprogrammet skulle også kunne påvise eventuel allerede opstået degradering af rørene ved ekstruderingen af materialet. Der blev også anvendt reologiske undersøgelser samt kontrol af smelteindeks for at afsløre eventuelle strukturelle ændringer i materialet. Mht. materialeegenskaber måltes brudstyrken og elasticiteten, ligesom den vel nok vigtigste materialeegenskab, nemlig revnevæksten, blev undersøgt.

Resultaterne fra testene af plastrørene viste ikke nogen som helst degradering i forbindelse med den vedvarende brinteksponering, der havde stået på i mere end fire år. Dette er en stærk indikation af, at de testede plastmaterialer, PE 80 og PE 100, er egnede til brug af brint.

1.2.2 Transmissionsnet - stålrør

Litteraturundersøgelser har vist, at der med stor sandsynlighed ikke vil være materialeproblemer ved statisk belastning med brint for de rørtyper, der anvendes i det danske gastransmissionsnet, X42, X52 og X70. Derimod anses dynamisk belastning, dvs. trykvariationer, for problematisk.

En undersøgelse i samarbejde med Energinet.dk har vist, at der i det danske gastransmissionsnet forekommer daglige trykvariationer på op til 20 bar, således at trykket varierer mellem ca. 50 og 70 bar.

Målet for ståltesten var derfor via dynamiske test at afdække, hvorvidt brint kunne initiere udmattelsesrevner.

Der blev udført dynamiske fuldskalaforsøg af tilfældigt udvalgte rørstykker, API 5L X70, med en diameter på 20 tommer og en godstykkelse på 7 mm, der var blevet skåret ud af det danske naturgastransmissionsnet. Rørstykkerne havde rundsømme, der var blevet svejst ved nedlægningen af rørledningerne i de tidlige firsere.

Disse rørstykker blev udsat for trykvariationer svarende til to gange det maksimale daglige udsving i det danske gastransmissionsnet. Antallet af trykvariationer svarer til 80 års drift. De efterfølgende analyseresultater af svejsningerne viste ingen tegn på revnevækst. Såfremt de anvendte rørstykker er repræsentative for det danske gastransmissionsnet, så indikerer afprøvningsresultaterne, at de i gastransmissionsnettet anvendte stålkvaliteter er kompatible med brint ved de trykvariationer, der forekommer.

2 Introduction and objectives

Very little information exists regarding the compatibility between long-term exposure and transportation of hydrogen in steel gas transmission pipelines and polyethylene gas distribution pipelines. A program was, therefore, set to study the transportation in a small-scale pilot grid at the field-test facilities of Danish Gas Technology Centre situated at the Scion-DTU research centre in Hørsholm, Denmark.

The test program included formerly used steel pipes from the Danish gas transmission grid and polymer pipes from the Danish and Swedish gas distribution grid.

The project partners were Danish Gas Technology Centre, Borealis AB and FORCE Technology.

Danish Gas Technology Centre was project manager and responsible for operation of the field test.

Borealis - one of the biggest suppliers of raw material from polyethylene for the production of pipes for e.g. pressure pipes for gas distribution - provided analytical services for the determination of compatibility problems between polyethylene pipes and hydrogen under long-term exposure.

FORCE Technology focused on dynamic testing and analysis of the steel pipes from the gas transmission grid.

3 Polymer pipe test and analysis

A dominant part of the natural gas distribution grid consists today of polyethylene pipes due to polyethylene's excellent track record as a reliable piping material with minimal maintenance. The reason for this is the inherent properties like its corrosion free nature, the possibility to create fully weldable systems, its high ductility and excellent low-temperature properties.

3.1 Test set-up

During the test phase the polymer pipes were exposed to pure hydrogen continuously for four years. The pressure was around 4 barg and the temperature around 8 °C. The pipes were placed as a normal gas distribution grid. See Figure 1.



Figure 1 Polymer test pipe grid

The program was devised so that a part of the test grid was to be dug up each year and analyses were performed on the pipes. In this way any form of influence on the integrity of the polyethylene pipe would be detected. The pipes were analysed before exposure to hydrogen, then the pipes were dug up after 1 year, 2 years, 3 years and 4 years of exposure.

3.2 Samples used in the analysis

The samples consisted of three distinctly different materials:

1. A yellow solid-wall s.c. PE 80 medium-density polyethylene (PE 80 MDPE).
2. An orange solid-wall s.c. PE 100 high-density polyethylene (PE 100 HDPE), called PE 100 type I.
3. A natural coloured pipe with an orange outer protective layer. The natural coloured material is an s.c. PE 100 high-density polyethylene (PE 100 HDPE), called PE 100 type II.

For each material, samples of various production years were included. Some of the pipes were also previously used in the Danish natural gas grid. The oldest pipes were subjected to natural gas for 20 years before exposure to H₂ in the pilot grid.

General note: CH₄ in text and figures should be read as Danish natural gas!

3.3 The analytical program

The annual analyzing program consisted of:

1. Structural changes in the polymer.
2. Consumption of antioxidants.
3. Change of tensile properties.
4. Change of slow crack growth properties of the material.
5. Surface oxidation.

The reason for this choice is that if no influence is detected in these properties then one can assume that polymer pipes are compatible with hydrogen and can safely be used, seen from a polymer structure property and pipe property point of view.

3.4 Results

3.4.1 General findings

During the investigations we found that there are basic quality level differences between pipes of different manufacturing years. Sometimes, this leads to an impression that there might be a certain relationship between exposure time to H₂ or previous usage of the pipe as a natural gas pipe. However, as can be seen below, there are basic quality level differences between pipes of different manufacturing years (see Figure 2).

3.4.2 Determination of changes in slow crack growth




Figure 2 CTL test resistance to slow crack growth of PE 80 pipes of different manufacturing years

3.4.3 PE 80 pipes

In the ESCR testing there were no indications of changes of CTL test resistance to slow crack growth with the time in the pilot hydrogen grid (see Figure 2). All variations are explained by the pipe manufacturing date and measurement variations, except for the probable outlier manufactured in 1987. The results are not depending on previous exposure to natural gas.

3.4.4 PE 100 pipes

The PE 100 type I and II follow the pattern of the previous analysis, i.e. no negative influence can be detected in CTL with time in the pilot hydrogen grid (see Figure 3). All samples show a very high resistance to slow crack growth. All samples are on a high level of resistance.




Figure 3 ESCR-CTL at 5 MPa/60 °C versus years of exposure to hydrogen of pipes not previously used

PE 100 type II previously used for four years in the natural gas grid compared with result for pipes not previously used with natural gas (CH₄) - see Figure 4. As found with PE 80, pre-exposure to natural gas does not influence the results.




Figure 4 ESCR-CTL at 5 MPa/60 °C versus years of exposure to hydrogen of pipes not previously used and a pipe used for four years in the natural gas grid

3.4.5 Determination of structural changes




Figure 5 Rheological results of PE 80 pipes of different manufacturing years




Figure 6 Rheology of PE 100 type II pipes, used for transportation of H₂ in the pilot grid, not previously used

Depending upon manufacturing year there are differences in molecular weight, Mw, molecular weight distribution, MWD and high molecular weight portion. The rheological result indicates clearly that different values rely on the basic quality level difference of the polymer manufactured in different years. Other changes within each group can be considered normal variations considering differences in polymer manufacturing and pipe manufacturing. There is no indication of changes caused by hydrogen exposure.

3.4.6 Determination of oxidative power - consumption of antioxidants

As can be seen from Figure 7 there is no effect from hydrogen transport on the antioxidative power of the additivation of the polymer pipes, measured as Oxygen Induction Time (OIT). This means that no interaction is found on the additivation of the polymer pipes from the hydrogen transport and the long-term integrity of the pipe is assured. Similar results have been found for PE 100 and pipes previously exposed to natural gas for up to 20 years prior to the hydrogen exposure. In the Gas pipe standard (EN 1555) an OIT of 20 minutes at 200 °C is deemed sufficient for a 50-year life time at 20 °C.




Figure 7 Oxygen Induction Time (OIT) versus years of hydrogen transport in the pilot hydrogen grid. Previously non-used pipes.

The scatter in the diagram is caused by samples of different years of manufacture, additive variation, sampling and measurement.

3.4.7 Determination of changes in tensile properties

The measurements are evaluated as changes in tensile modulus and elongation at break.

As can be seen in Figure 8 and Figure 9, it is neither possible to detect any negative influence on tensile modulus nor in elongation at break. There could be a possible increase of modulus with time, however, the change in comparison to the scatter in the test and the fact that samples of different manufacturing year were used made the observation clearly uncertain.




Figure 8 Elongation at break and tensile modulus versus years of exposure to hydrogen of pipes previously used for 20 years in the natural gas grid




Figure 9 Elongation at break and tensile modulus versus years of exposure to hydrogen of pipes not previously used

3.5 Polymer testing conclusion

The overall conclusion is that four years of continuous hydrogen exposure caused no influence on PE 80 or PE 100 natural gas pipes.

The below list shows the detailed conclusions:

1. No influence on the basic structure on the pipes measured with rheology acc. to ASTM 4440-95a.
2. No influence on additivation/oxidative strength on the pipes measured with oxygen induction time (OIT) acc. to EN 728.
3. No influence on the pipes measured as elongation at break and tensile modulus ISO 527.
4. No influence on the slow crack growth properties measured as CTL at 5 MPa/60 C acc. to ISO6252-1992 / ASTM1473 F.
5. Even the pipes previously used for 20 years in the natural gas grid in Denmark do not differ significantly from fresh unused pipes in any of the above mentioned properties.
6. The strongest influence on the properties is the year of manufacture of the pipes and possible underlying year of manufacture of polymer raw material indicating quality level variations at delivery. The differences, however, are not significant.

Further details can be found in Annex 1.

4 X70 steel natural gas transmission pipeline test and analysis

4.1 Introduction and objectives

Most studies aiming to describe the fatigue limits of existing pipelines for hydrogen gas distribution are based on fracture mechanics principle and it was found of less use to try to reproduce this work. Instead, it was decided to make **a series of full-scale test exposing pipes to fluctuating pressures of hydrogen gas.**

4.1.1 The object of the steel pipe test

The objective was to analyze the effect on fatigue life of existing natural gas transmission lines with hydrogen replacing natural gas. The test and analysis focused on the effect of hydrogen on fatigue cracking in pipeline girth welds.

Full-scale tests were performed using cut-out API 5L X70 pipe sections 20 inch diameter by 7 mm WT retrieved after more than 20 years in the Danish natural gas transmission system. The pipe sections contained field girth weld (SMAW) made during the installation of the pipeline in the eighties. The weld quality is assumed to represent the Danish gas lines.




Figure 10 Test unit for steel pipe dynamic testing

The internal test environment consisted of 100% hydrogen gas at fluctuating pressures representing the daily peak-to-peak variation in the gas transmission line. The maximum pressure was 70 bar and the maximum pressure amplitude used was 30 bar.

Two test series were conducted with increasing pressure amplitude from 20 bar to 30 bar.




Figure 11 Test series 1




Figure 12 Test series 2

The pressure cycle variation frequency was less than 0.0017 Hz and each test series was run for 15,000 or 30,000 cycles. 15,000 cycles correspond to 40 years operation with one pressure cycle per day.

4.2 Analysis

The girth welds were checked prior to test and again after the completed test cycle by ultrasonic examination. No cracks were observed and the test specimen continued in test for the next period.




Figure 13 Cross section of test pipe wall (API5LX70) with girth weld

The girth welds were dissected and subjected to metallographic and MPI examination in addition to the ultrasonic testing in order to describe possible defects and defect growth in the weld zones. No indications of any fatigue related fractures were found.




Figure 14 Close up section of girth weld. No indication of fatigue cracking can be observed.

4.3 Conclusion of steel tests

The dynamic testing equivalent of 80 years service with twice the maximal pressure variations found in the Danish gas transmission system (i.e. 2 x 15 bar equal to 40 to 70 bar in 30,000 cycles) did not show any defect growth. This provides some confidence in addition of hydrogen to the existing Danish gas transmission pipeline provided it is free of significant weld defects.

Further details can be found in Annex 2.

5 References

1. Andersen, Juhl, Pedersen, Myken, Iskov; Brint som energibærer; Dansk Gasteknisk Center 1999; ISBN 87-7795-172-7.

APPENDIX 1: Borealis Innovation Project Report

Select the report type

	Technical report
X	Research report
	Commercial report

1. General Project Data

OA/IP/ Project name
BU no.

	Support work for Danish gas research centre on hydrogen transport in PE natural gas pipes.
--	--

2. General Report Data

5.1.1.1.1.1.1Date 5.1.1.1.1.1.2Report ID no.

2010-06-30

Title

Summary report on a four year study of hydrogen transport in Polyethylene natural gas pipes.

Authors

Mats Bäckman

Background

It has become ever clearer that the resource of natural gas is an energy source which will be less important in the future due to limitations in natural reserves. In order to prepare for the future the gas industry is looking at alternative fuel gases, one such fuel gas is hydrogen.

A dominant part of the natural gas distribution grid consists today of polyethylene pipe due to its excellent track record as a reliable piping material with minimal arising problems or maintenance. The reason for this is the inherent properties like its corrosion free nature, the possibility to create fully weldable systems, its high ductility and excellent low temperature properties.

In order to prepare for a future use of hydrogen as a fuel gas it became evident to the Danish Gas research Centre that very little information existed regarding the compatibility between long term exposure and transportation of hydrogen in Polyethylene gas pipelines. A program was therefore set to study the transportation in a small scale pilot grid at the research centre in Hørsholm, Denmark.

Borealis being one of the biggest suppliers of raw material from Polyethylene for the production of pipes for e.g. pressure pipes for Gas distribution volunteered to provide analytical services for the determination of any compatibility problems between polyethylene pipes and hydrogen under long term exposure.

The program was devised so that part of the grid was to be dug up each year and analysis performed on the pipes, in this way any form of influence on the integrity of the polyethylene

pipe would be detected. The pipes were analysed before exposure to hydrogen, then the pipes has been dug up after 1 year, 2 years, 3 years and 4 years of exposure. The exposure was made in a circulation grid so that both pressure and a linear speed were maintained in a closed system. Some of the pipes have also previously been used in the Danish natural gas network. Lengths of pipes has been cut out of the network and replaced, the pipes has then been fitted into the pilot grid in Hörsholm and subjected to H₂ there and of course been dug up as described above. The oldest pipes have been subjected to natural gas for 20 years before exposure to H₂ in the pilot grid.

Short summary

This report contains data from four years of hydrogen transport in PE natural gas pipes, in the pilot grid built up at Danish gas research centre in Hörsholm, Denmark. The pipes are both unused pipes as well as pipes that have a prehistory of 4, 5 and 20 years of service in the Danish natural gas network. This study has focused on detecting structural changes (by MFR/FRR and rheology), changes in antioxidative power (Oxygen induction time), previous deterioration of oxidative power, surface oxidation from pipe manufacturing (Fourier transform infrared analysis), changes in mechanical properties (E-modulus/ elongation at break) as well as changes to the resistance to slow crack growth (constant tensile load test).

No detrimental effect has been found by the exposure to hydrogen nor has any effect of a prior use in the Danish natural gas network up to 20 years been found.

Conclusions

We can see from the four years of exposure to hydrogen in the pilot grid in Denmark that.

- No adverse effect is found on either PE80 pipes or on two types of PE100 in terms of its:
- Oxidative resistance measured with oxygen induction time;
- Mechanical properties measured as e-modulus and elongation at break;
- Slow crack growth resistance measured with CTL at 60 C;
- Structural build up measured with rheology
- MFR5, MFR21 and FRR21/5
- We see no reason why MDPE PE80 or HDPE PE100 can't be used as media pipes for hydrogen transport.

We have also found that:

- There is no adverse effect if the pipes have previously been used for natural gas transport, still no effect on the above-mentioned properties;
- The pipes that have been exposed to 20 years of usage as natural gas transport pipes show the same properties as unused pipes in the above-mentioned properties;
- Pipes with a total of 24 years of usage, natural gas transport + hydrogen

transport show the same properties as virgin pipes.

Actions / proposals

Product(s)

PE100, PE80

Distribution

Henrik Iskov (DGC)

Investigation of Natural gas pipes for Hydrogen gas transportation.

Introduction:

It has become ever clearer that the resource of natural gas is an energy source which will be less important in the future due to limitations in natural reserves. In order to prepare for the future the gas industry is looking at alternative fuel gases, one such fuel gas is hydrogen.

A dominant part of the natural gas distribution grid consists today of polyethylene pipe due to its excellent track record as a reliable piping material with minimal arising problems or maintenance. The reason for this is the inherent properties like its corrosion free nature, the possibility to create fully weldable systems, its high ductility and excellent low temperature properties. In order to prepare for a future use of hydrogen as a fuel gas it became evident to the Danish Gas research Centre that very little information existed regarding the compatibility between long term exposure and transportation of hydrogen in Polyethylene gas pipelines. A program was therefore set to study the transportation in a small scale pilot grid at the research centre in Hørsholm, Denmark.

Borealis being one of the biggest suppliers of raw material from Polyethylene for the production of pipes for e.g. pressure pipes for Gas distribution volunteered to provide analytical services for the determination of any compatibility problems between polyethylene pipes and hydrogen under long term exposure.

The program was devised so that part of the grid was to be dug up each year and analysis performed on the pipes, in this way any form of influence on the integrity of the polyethylene pipe would be detected. The pipes were analysed before exposure to hydrogen, then the pipes has been dug up after 1 year, 2 years, 3 years and 4 years of exposure. The exposure was made in a circulation grid so that both pressure and a linear speed were maintained in a closed system. Some of the pipes have also previously been used in the Danish natural gas network. Lengths of pipes has been cut out of the network and replaced, the pipes has then been fitted into the pilot grid in Hørsholm and subjected to H₂ there and of course been dug up as described above. The oldest pipes have been subjected to natural gas for 20 years before exposure to H₂ in the pilot grid.

Abbreviations used:

SCG = Slow crack growth

OIT= Oxygen Induction Time

ESCR = Environmental Stress Cracking

CTL = Constant Tensile Load, name of test method.

PE100 = Polyethylene pipe material fulfilling classification of MRS 10,0 MPa

PE80 = Polyethylene pipe material fulfilling classification of MRS 8,0 MPa

MRS= Minimum required strength at 50 years

DGC= Danish Gas research Centre

FTIR= Fourier Transform Infra Red analysis

MFR= Melt Flow Rate

FRR= Flow Rate Ratio

ISO= International Organisation for Standardisation

CH₄= Natural gas

Experiments:

After each year of exposure to hydrogen gas and its references the planned experiments was to determine if there had been any 1) Structural changes in the polymer 2) Consumption of anti-oxidants 3) Change of Tensile properties 4) Change of slow crack growth properties of the material 5) Change of MFR/FRR. The reason for this choice is that if no influences are detected in these properties then one can assume that the media polymer pipe are compatible and can safely be used, seen from a polymer structure-property-pipe property point of view.

Samples used in the analysis:

It has been found that the samples consist of three distinctly different materials namely 1) a yellow solid wall s.c. PE80 medium density polyethylene (PE80 MDPE) 2) An Orange solid wall s.c. PE100 High density polyethylene (PE100 HDPE) hereinafter called PE100 type I 3) A natural coloured pipe with an Orange outer protective layer, the natural coloured material is a s.c. PE100 High density polyethylene (PE100 HDPE) hereinafter called PE100 type II.

Determination of structural changes:

Pressure pipe PE polymers are high molecular weight materials with a broad molecular weight distribution and the physical properties of the polymer are determined to a large extent by the high molecular weight portion of the material. There are two main ways of determining the structure, molecular weight and molecular weight distribution either it can be determined by Size Exclusion Chromatography (SEC alt GPC) or it can be determined by Rheology. Since we are to analyse high molecular weight materials with a broad molecular weight distribution the choice fell upon Rheology since this is more sensitive to changes in the high molecular portion and these changes are coupled to physical properties of the material. In these rheological measurements one can define certain indexes. In this study we have chosen to use $\eta_{2,7\text{KPa}}$ which corresponds to the average molecular weight Mw, $\text{SHI}_{2,7/210\text{KPa}}$ which corresponds to the molecular weight distribution MWD as well as $\eta_{747\text{Pa}}$ which roughly correspond to the high molecular weight tail Mz (ref 1,2) (see also ASTM 4440-95a and EP1137707-rheological description). The measurement principle is to melt and subject a melt pool of the polymer to ever increasing shear rate (oscillating speed in Rheometer), (see Experimental set-up, Rheometry), since PE is a s.c. shear thinning polymer it will mean that the viscosity will be reduced with increasing shear speed. The way the viscosity decrease, with the shear speed depends on the molecular structure, MWD, Mw etc. By analysing the curve according to the above mentioned indexes detailed information about the structure of the particular material can be achieved.

Determination of Oxidative power - consumption of antioxidants:

In order to detect interaction between the transported medium and antioxidant (the pipe grades contains mainly phenolic antioxidants) the so called Oxygen Induction Time (OIT, acc EN728) was chosen as it gives a quick and reliable measurement of the oxidation power of the addition in the polymer. This has been determined at two temperatures to increase the accuracy of the determination. However many gas pipe material contains UV-stabilisers which also act as antioxidants at temperatures below 120 C. Since the analysis is performed at 200 C and 210 C this capability is not captured. However the analysis will show if an interaction between the antioxidant and transported media has taken place and the antioxidative power will be at least that shown.

The measurement principle is to let in pure oxygen into the heated furnace (see Experimental set-up, Oxygen induction time), as long as the antioxidant works no oxidation takes place on the polymer but once it is consumed the polymer starts to oxidise and energy is released this energy is recorded (see Experimental set-up, Oxygen induction time, diagrams) and the time to antioxidant depletion can be recorded. This test normally takes place at 200 or 210 C, the acceleration factor per 10 C is ca 2,3-2,5 which means that a result of 25 min at 210 C would correspond to roughly 354-1730 years at 20 C. The standard demand of 20 min at 200 C is roughly equal to 123-553 year at 20 C. However normally some losses to the transport media are calculated, especially in the case of water transport and it is a long extrapolation, therefore the high safety margin in the standard (see ref 3) for the demand for oxidative stability.

Determination of changes in Tensile properties:

In order to detect changes in the basic mechanical properties of the Pipes we have chosen to test the pipes according to ISO 527-2/1B and have determined yield point, break point, elongation at break as well as the tensile modulus of the pipe.

The measurement principle is to draw a dumbbell until failure and from this curve extract different values like yield point etc (see Experimental set-up, tensile testing and diagram)

Determination of changes in Slow Crack Growth:

In order to be able to use specimens prepared out of the pipes, we have chosen a method called CTL (ISO 6252-1992) fitted with notches according to ASTM 1473 F of 40 % notch depth. The test was performed at 5 MPa and 60 °C in a 10 % solution of Igepal 720 in water.

The measurement principle is to pre-create a notch in a sample and use temperature as well as a stress cracking media (such testing is normally called ESCR, Environmental stress cracking) to accelerate the growth of the crack (see Experimental set-up, Slow crack growth, CTL). The reason is that if a PE pipe fails in practise it will be because of slow crack growth and this can be started by e.g. rocks impinging the pipe because of soil settlement, poor welding at installation etc. To have a good resistance to slow crack growth is vital for the long term integrity of the pipe.

Determination of MFR / FRR:

In order to determine any changes in the basic parameters MFR5 and FRR21/5 measurements according to ISO 1133 was performed.

The measurement principle is to melt polymer in the apparatus (see Experimental set-up, MFR ISO 1133), then load the melt pool with a certain weight (in this case 5 & 21,6 Kg) and record the amount of polymer flowing out per time unit. This is a standard way of having a quick measurement of Mw (MFR5) and MWD (FRR21/5) however much less accurate than the rheological evaluation referred to above.

Further determination:

In order to detect any prior negative influence from the pipe extrusion, a measurement of the carbonyl index or in other words the surface oxidation of the inner surface of the pipes was performed. The surface oxidation was measured with Fourier Transform Infra Red (FTIR) technique (see experimental set up).

The measurement principal is to shine infrared light of different wave lengths through a polymer sample, depending upon the chemical nature of the composition (e.g. carbonyl group) and amount, the material will absorb the infra red light and an analysis of the wave length versus absorption will reveal the chemical nature and amount of species in the polymer.

**Experimental set up:
MFR ISO 1133:**

Performed according to ISO 1133, principle of measurement and equipment see below:




Figure 1 MFR apparatus



Slow crack growth CTL, ISO 6052-1992, Notch acc ASTM F1473

Figure 2 Surface-active solution, Igepal CO-720 at 60 C, stress level 5,0 MPa.

Tensile testing, ISO 527-2/1B**Tensile properties**

ISO 527

Specimen from pipe: ISO 6259 EN 638

**Figure 3 Tensile test set up and evaluation**

Rheology ASTM 4440-95a, (Detailed description, see Patent EP1137 707 rheology section):




Figure 4 Rheometer Physica MCR 300






Figure 5 General measurement set-up

Oxygen Induction time, OIT, EN 728:**Figure 6 Oxygen induction time (OIT) apparatus****Figure 7 Oxygen induction time evaluation**

Fourier Transform Infrared Analysis (FTIR), determination of pipe surface oxidation:





Figure 8 Fourier transform infrared analysis apparatus and principle

Results

Basic quality level of pipe of different manufacturing year:

During the investigations we have found that there are basic quality level differences between pipes of different manufacturing years. This leads sometimes to an impression that there might be a certain relation between exposure time to H₂ or previous usage of the pipe as a Natural gas pipe. However as can be seen below there are basic quality level differences between pipes from different manufacturing year (see fig. 9 & 10) Since pipes of these different manufac-

turing dates in some diagrams are mixed, in some of the exposure experiment evaluations, we receive a larger scatter than normally would be received.




Figure 9 CTL test resistance to slow crack growth of PE80 pipes of different manufacturing years.

This basic variation in quality level is most likely inherent from the polymer manufacturing process, since no detectable surface oxidation or other quality problems with the pipes can be found. Please also note there is one outlier in performance in among the pipes manufactured in 1987, if this is due to the polymer manufacturing or an unusual variation in testing (however not likely) has not been possible to determine with high accuracy. The pipe manufacturing can't increase the quality level in the pipe if anything rather the opposite. All other variations within each pipe group are normal variations in the test.

Similar variation can also be seen in the rheology i.e. as previously explained the basic structure of the material (see also: Experiments: Determination of structural changes). This is further evidence that this is due to the polymer manufacturing since especially the slow crack growth property is dependent upon basic structure of the material (see fig below), however the basic structure is not revealing the whole story on slow crack growth since both comonomer content and comonomer placement plays an equally important role.




Figure 10 Rheological results of PE80 pipes of different manufacturing years

This diagram reveals that depending upon manufacturing year there are differences in molecular weight, Mw, molecular weight distribution, MWD and high molecular weight portion. These differences are not very big however in the coming text regarding results it may appear that e.g. the contact with hydrogen in prolong times may increase the Mw ($\eta_{2,7\text{KPa}}$) and Mz ($\eta_{747\text{Pa}}$). This is a mere illusion and depends on the basic quality level difference of the polymer manufactured in different years (see e.g. fig. 11) other changes within each group can be considered normal variations considering differences in polymer manufacturing and pipe manufacturing.

This problem has not arisen that pronounced, in the PE100 samples since the number of different manufacturing years are much fewer and closer together as well as they are of two different kinds, one single wall coloured through orange PE100 and one natural coloured PE100 with an orange protective outer layer. The two PE100 has been separated, analysed and reported individually.

Determination of structural changes:

PE80 pipes not previously used:

As can be seen from the diagram below it is evident that a PE80 material that has been subjected to H₂ transportation for up to 4 years does not show any evidence of structural changes (see fig. 11 below)




Figure 11 Rheology of PE80 pipes used for transportation of H₂ in the pilot grid.

The indication, that there is an increase of the $\eta_{747\text{Pa}}$ (Mz) after four years of exposure, is merely because the pipes are of different year of manufacture and the associates quality difference. The two first points are from pipes produced in 1986, the other points are from pipes produced in 2001 and 2002. In conclusion no indication is found of any adverse effects on the structure of the material.

PE80 pipes used for 5 years in the natural gas transportation grid in Denmark:

As can be seen in the diagram below (see fig 12 below) there is neither any negative influence from the use of the pipes for transporting H₂ in the pilot grid for three years, even though the pipes has previously been used for five year for transporting natural gas in Denmark. Please also note that there are practically no difference between a non used reference pipe and a reference pipe that has been used for five years of natural gas transportation. This is indicating that there is no adverse effect also from 5 years of transportation of natural gas.




Figure 12 Rheology of material used for transportation of H₂ in the pilot grid previously used for 5 years of natural gas transportation.

PE80 pipes used for 20 years in the natural gas transportation grid in Denmark:

As can be seen in the diagram below (see fig 13 below) there is neither any negative influence from the use of the pipes for transporting H₂ in the pilot grid for 3 years, even though the pipes has previously been used for 20 year for transporting natural gas in Denmark. Please also note that there is practically no difference between a non used reference pipe and any of the pipes that has been used for 20 years of natural gas transportation. This is indicating that there is no adverse effect also from 20 years of transportation of natural gas and on top of this, 3 years of hydrogen transportation. The variation seen in the diagram is mainly because there is different manufacturing dates but also sample and test variations (manufacturing year indicated in the diagram).

The $\eta_{747\text{Pa}}$ of the 1986 pipe after two years of hydrogen exposure is an outlier.




Figure 13 Rheology of material used for transportation of H₂ in the pilot grid previously used for 20 years of natural gas transportation. The manufacturing years is indicated in the diagram.

In conclusion no adverse effect has been seen from transporting H₂ in polyethylene PE80 natural gas pipes. Neither has such an effect been seen even if the pipes have previously been used for up to 20 years of natural gas transportation. As well no difference has been seen in a previously unused pipe and a pipe that has seen the combined effect of 20 years of usage for transporting natural gas and 3 years of hydrogen gas transportation.

PE100 pipes not previously used:

PE100-type I:

As can clearly be seen in the diagram below (see fig 14 below) there is no effect on the PE100 type I material from the use of the pipes in the pilot hydrogen grid in Denmark for up to 4 years. In essence the results are the same throughout the test program.




Figure 14 Rheology of PE100 type I pipes, used for transportation of H2 in the pilot grid.

PE100-type II:

Also in the case of PE100 type II pipes, one can clearly see in the diagram below (see fig 15 below) that there is no effect on the PE100 type II pipe from the use of the pipes in the pilot hydrogen grid in Denmark for up to 4 years. The variation seen is a combination of manufacturing year, sample and test variations.




Figure 15 Rheology of PE100 type II pipes, used for transportation of H2 in the pilot grid, not previously used.

PE100 type II pipes used for 4 years in the natural gas transportation grid in Denmark:

In the case of the PE100 type II pipes, a pipe that has previously used for 4 years in the Danish natural gas pipe grid has also been evaluated for 2 years in the hydrogen transportation grid in Denmark.

As can be seen in the diagram below (see fig 16) there is no difference between a non used pipe or a pipe that has been subjected to 1 or 2 years of hydrogen transport without previous use and the pipe that has first been used for 4 years of natural gas transportation and then subjected to 2 years of hydrogen transport.




Figure 16 Rheology of PE100 type II pipes, used for transportation of H₂ in the pilot grid compared to the combined effect of 4 years of natural gas transportation followed by 2 years of H₂ transportation.

In conclusion there is no adverse effect from the transportation of hydrogen on PE100 type I or PE100 type II for up to 4 years. There was as well no effect seen on PE100 type II from the combined effect of use of 4 years for transportation of natural gas followed by 2 years of hydrogen transport.

Determination of Oxidative power - consumption of antioxidants:

PE80 pipes not previously used:

As can be seen from the diagram below (see fig 17) we have no effect from hydrogen transport on the antioxidative power stemming from the additivition of the polymer pipes, measured as oxygen induction Time (OIT). This means that no interaction is found on the additivition of the polymer pipes from the hydrogen transport and the long term integrity of the pipe is assured. In the Gas pipe standard (EN 1555) an OIT of 20 minutes at 200 C is deemed sufficient for a 50 year life time at 20 C, we are here looking at 2-3 times longer results even after 4 years of exposure.




Figure 17 Oxygen induction time (OIT) versus years of hydrogen transport in the pilot hydrogen grid. Previously non used pipes

The scatter in the diagram stems from samples of different years of manufacturing, additive variation, sampling and measurement.

PE80 pipes used for 5 years in the natural gas transportation grid in Denmark:

Also in the case where the pipes has been pre-used for 5 years for natural gas transport and then transportation of hydrogen in the pilot grid, it is not possible to detect any influence on the oxygen induction time (OIT) at 200 or 210 C up to 3 years of hydrogen transport (see fig 18). Hence the long term antioxidative power at 20 C is maintained. Interesting to note is that there is no significant difference between a non used reference and a reference used for 5 years natural gas transport or a pipe used for 5 years natural gas transport and on top 3 years of hydrogen transport.




Figure 18 Oxygen induction time (OIT) versus years of hydrogen transport in the pilot hydrogen grid. Pipes previously used for 5 year in the natural gas grid in Denmark.

PE80 pipes used for 20 years in the natural gas transportation grid in Denmark:

As in the previous cases also when the pipe, prior to the hydrogen transport in the test grid, has been used for 20 years in the natural gas grid in Denmark one can't detect any negative influence on the oxygen induction time (OIT) neither on 210 C or at 200 C (see fig 19 below). Also in this case it is interesting to note that there is no difference between a previously not used pipe and a pipe that has been in service for 20 years as well as pipes that has been in service for 20 years plus 3 years of hydrogen transport in the pilot hydrogen gas grid.




Figure 19 Oxygen induction time (OIT) versus years of hydrogen transport in the pilot hydrogen grid. Pipes previously used for 20 year in the natural gas grid in Denmark.

PE100 pipes not previously used:

PE100-type I:

In the PE100 type I material which has not previously been used for natural gas transportation, it is also clear in this case that no negative influence has taken place on the oxygen induction time (see fig 20 below). Most of the measurements are done at 210 C and only some complementary measurements at 200 C, however it does not influence the conclusion.




Figure 20 Oxygen induction time (OIT) versus years of hydrogen transport in the pilot hydrogen grid. Pipes previously not used.

PE100-type II:

The result of the not previously used pipes by PE100 type II is the same as in the above referred, there is no indication that there are any interaction between hydrogen and the oxygen induction time (OIT) (see fig 21 below).




Figure 21 Oxygen induction time (OIT) versus years of hydrogen transport in the pilot hydrogen grid. Pipes previously not used.

PE100 type II previously used for 4 years in the natural gas grid.

Among the PE100 type II samples we have also pipes that has first been used for four years in the natural gas grid then used in the pilot grid for two years hydrogen transport. As can be seen in the diagram below (see fig 22 below) there is no difference between the sample that has been 4 years in the natural gas grid plus two years in the hydrogen grid and the sample that was not previously in the natural gas grid with two years of exposure to hydrogen or for that matter to a sample that has not been used at all (see references in the fig below).




Figure 22 Oxygen induction time (OIT) versus years of hydrogen transport in the pilot hydrogen grid. A sample previously used in comparison to pipes previously not used.

Determination of changes in Tensile properties:

PE80 pipes previously not used:

In order to further investigate any possible influence we have also performed measurements of tensile properties as well as Modulus determinations on the samples. The measurements are evaluated as changes in Tensile modulus and Elongation at break.

As can be seen in the diagram below, it is not possible to neither detect any negative influence to tensile modulus nor in elongation at break (see fig 23 below). There could be a possible increase of modulus with time however the change in comparison to the scatter in the test and the fact that samples of different manufacturing year has been used makes the observation uncertain.




Figure 23 Elongation at break and Tensile modulus versus years of exposure to hydrogen of pipes previously not used.

PE80 pipes used for 5 years in the natural gas transportation grid in Denmark:

In the case of pipes that has previously been used for five years in the natural gas grid we can see that also in this case the pipes do not show any negative changes with the years of use in the pilot hydrogen gas grid (see fig 24).




Figure 24 Elongation at break and Tensile modulus versus years of exposure to hydrogen of pipes previously used for five years in the natural gas grid.

PE80 pipes used for 20 years in the natural gas transportation grid in Denmark:

In the case of pipes that have been used for 20 years in the natural gas grid prior to the use in the hydrogen pilot grid, we can also in this case, not detect any negative influences (see fig 25). Instead all measurements are within a reasonable variation with a possible last outlier. As a reference a pipe, a pipe that were used for 5 years in the natural gas grid without any use in the pilot hydrogen grid, was depicted. The manufacturing year of the pipe is indicated in the diagram.




Figure 25 Elongation at break and Tensile modulus versus years of exposure to hydrogen of pipes previously used for 20 years in the natural gas grid.

PE100 pipes not previously used:

PE100-type I:

In the case of PE100 type I, there are unfortunately missing some initial data on elongation at break on reference and early exposure. However as can be seen the elongation at break at longer exposure times is at a very good level ca 600 % (a result is approved if >350 % according to EN standards) and there is no indication of any influence from years in the hydrogen gas grid (see figure 26). The tensile modulus does not show any negative influence either (see fig 26). Though a small tendency of increased modulus could be indicated, however there is a high likelihood that this is due to sample and measurement variations.




Figure 26 Elongation at break and Tensile modulus versus years of exposure to hydrogen of pipes previously not used.

PE100-type II:

In the case of PE100 type II the situation is the same there are no indications of negative effects (see fig 27) all variation is within sample preparation and measurement variations.




Figure 27 Elongation at break and Tensile modulus versus years of exposure to hydrogen of pipes previously not used.

PE100 type II previously used for 4 years in the natural gas grid.

Below one can see a comparison between a pipe that first was used for four years in the natural gas grid before used for two years in the pilot hydrogen gas grid and previously not used pipes. As can be seen (see fig 28) there is no difference between any of the pipes i.e. no negative effect seen.




Figure 28 Elongation at break and Tensile modulus versus years of exposure to hydrogen of pipes previously not used and a pipe used first for 4 years in the natural gas grid.

Determination of changes in Slow Crack Growth:

PE80 pipes previously not used:

In the ESCR we have the same situation as in the other properties there are no indications of changes in this property with the time in the pilot hydrogen grid (see fig 29 below). In this diagram no exposure and 1 year exposure of pipes with a prehistory of 5 years natural gas transportation has been used as true references are missing.




Figure 29 ESCR-CTL at 5MPa /60 C versus years of exposure to hydrogen of pipes previously not used.

PE80 pipes used for 5 years in the natural gas transportation grid in Denmark:

In the pipes that have prior to the use in the pilot hydrogen gas grid been used for 5 years in the natural gas grid, the situation is the same no detectable influence can be seen in the slow crack growth (see fig 30).




Figure 30 ESCR-CTL at 5MPa /60 C versus years of exposure to hydrogen of pipes previously used for 5 years in the natural gas grid.

PE80 pipes used for 20 years in the natural gas transportation grid in Denmark:

Also in the case of pipes previously used for 20 years in the natural gas grid, there is no detectable influence from the use in the pilot hydrogen grid (see fig 31). All variations are explained by the pipe manufacturing date and measurement variations, except the last sample which is a probable positive outlier. Year of manufacture indicated in the diagram.




Figure 31 ESCR-CTL at 5MPa /60 C versus years of exposure to hydrogen of pipes previously used for 20 years in the natural gas grid.

PE100 pipes not previously used:

PE100-type I:

The PE100 type I follow the pattern of the previous analysis no negative influence can be detected in CTL with time in the pilot hydrogen grid (see fig 32). All samples show a very high resistance to slow crack growth.




Figure 32 ESCR-CTL at 5MPa /60 C versus years of exposure to hydrogen of pipes previously not used.

PE100-type II:

Also in the case of previously non used pipes the pattern is the same no influence of years in the pilot hydrogen gas grid can be seen (see fig 33). All samples are on a high level of resistance.




Figure 33 ESCR-CTL at 5MPa /60 C versus years of exposure to hydrogen of pipes previously not used.

PE100 type II previously used for 4 years in the natural gas grid.

In the case of PE100 type we have also a pipe that before 2 years of use in the pilot hydrogen gas grid, have been used for 4 years in the natural gas grid. This pipe is depicted in comparison to pipes not previously used in the natural gas grid with different exposure time in the pilot hydrogen grid (see fig 34). As can be seen (fig 34) no difference between a pipe that has not been used (see references) and pipes not used in the natural gas grid but different no of years in the pilot grid and the pipe that first was 4 years in the natural gas grid and then exposed for two years in the pilot hydrogen grid, can be detected.




Figure 34 ESCR-CTL at 5MPa /60 C versus years of exposure to hydrogen of pipes previously not used and a pipe used first for 4 years in the natural gas grid.

Surface oxidation of pipe samples:

All samples were analysed for surface oxidation but no surface oxidation was found.

Report on surface oxidation of the first round of test 2004 (Borealis)**MEMO**

To Mats Bäckman

From Ann-Christin Augustsson

Date 06.09.2004


Total pages 3 (including this)

Subject TR44369: OIT and FTIR analysis of pipes tested for H₂-gas transport


TR44369: OIT and FTIR analysis of pipes tested for H₂-gas transportOIT analyses

OIT 210°C was determined on the inner surface – 0.2mm, in the middle of the pipe wall and on the outer surface of the pipes. On the orange reference, sample 6, samples were taken from four positions around the circumference (pos 1-4 in the table below) and on two additional positions along the pipe (pos 5 and 6). The results are found in the table.

Sample	OIT 210°C, min		
	inner surface- 0.2mm	middle	outer surface
P5, MDPE 3802Y	28 23	28 37	28 31
P4, MDPE 3802Y	34 29	34 32	27 31
P3, ref MDPE 3802Y	no sample		
P2, MDPE 3802Y	24 24	33 31	32 22
P1, MDPE 3802Y	26 27	32 37	30 30
Ref, HDPE TUB122:			
pos 1	38 49	56 49	21 9
pos 2	60 48	55 57	32 45
pos 3	38 54	54 55	39 45
pos 4	60 62	55 57	31 36
pos 5	62 63	61 57	40 49
pos 6	60 56	61 70	36 50
P3, HDPE TUB122	68 73	42 63	49 49
P6, HDPE TUB122	72 78	54 66	44 50


FTIR, analysis of inner surfaces (ATR, Golden Gate)**MDPE-pipes:**

Black curve: inside pipe wall, blue: P1, red: P2, violet: P4, green: P5.


HDPE-pipes:

Blue curve: inside pipe wall, red: reference, black: P6, green: P3.


Weak carbonyl groups were observed on the orange HDPE pipes. The wavenumber (1732cm^{-1}) indicates that the carbonyls derive from stabilisers and/or pigments. Significant surface oxidation was not detected on any of the pipes.


Report on surface oxidation of the second round of test 2007**FTIR spectra, surface analysis (ATR)**


The peaks at 1262cm^{-1} , 1098cm^{-1} and 1030cm^{-1} on the surface of the reference sample derives from silicone oil





The peaks at 1262cm^{-1} , 1081cm^{-1} and 1030cm^{-1} derive from silicone oil

















Report on surface oxidation of the third round of test 2008 (Borealis)**MEMO**

To Mats Bäckman

From Ann-Christin Augustsson

Date 12.01.2009

Total pages 3 (including this)

Subject TR83565: FTIR analyses of pipes from Dansk Gastekniskt Center

TR83565: FTIR analyses of pipes from Dansk Gastekniskt Center**Background**

BU Pipe has decided to support a project headed by Dansk Gastekniskt Center on Hydrogen transport i Natural as pipelines. The decision was that we should support them with Analytical expertise and analysis in the PE pipes which are exposed to hydrogen in return we will have available the outcome of the data from this project and other hydrogen project in a bigger program of which this project are a part of.

They have now excavated pipes after 2 year of exposure and we now have to perform an analysis program on reference (non exposed) and the excavated exposed pipes.

(For analytical results on pipes exposed for 1 year, see TR74655.)

Analyses

The following tests were performed:



Surface oxidation by FTIR using the ATR accessory Golden Gate

FTIR results



The results do not indicate that the hydrogen exposure has deteriorated the materials.

The carbonyl peaks with maxima around 1735 cm^{-1} detected on the surface of some of the pipes are most probably due to ester groups in the stabilisers and not oxidation.

Spectra are attached.

FTIR spectra, samples 2A1 – 2A8

Carbonyl region. 2A1 (grey curve), 2A2 (purple), 2A3 (blue), 2A4 (red), 2A5 (pink), 2A6 (black), 2A7 (green), 2A8 (purple).

FTIR spectra, samples 2B1 – 2B8

Carbonyl region. 2B1 (red curve), 2B2 (blue), 2B3 (purple), 2B4 (grey), 2B5 (purple), 2B6 (green), 2B7 (black), 2B8 (pink).

Determination of changes in MFR and FRR:

Also in the MFR and FRR there is no indication of any deterioration of the properties. In principle these measurements correspond to the rheological measurement however the accuracy and sensitivity of MFR/FRR is much lower than rheology, so since we could not detect any changes in rheology it is expected to find this also in this measurement. Some examples of the evolution over the exposure time and prehistory can be seen below, also a table of all performed measurement is attached (please see fig 35-37 below).




Figure 35 MFR5, MFR21, FRR21/5 C versus years of exposure to hydrogen of pipes previously not used.




Figure 36 MFR5, MFR21, and FRR21/5 versus years of exposure to hydrogen of pipes previously used for 20 years in the natural gas grid.




Figure 37 MFR5, MFR21, and FRR21/5 versus years of exposure to hydrogen of pipes previously not used.

Conclusion:

We can see from the four years of exposure to hydrogen in the pilot grid in Denmark that.

- No adverse effect is found on either PE80 pipes or on two types of PE100 in terms of its:
- Oxidative resistance measured with oxygen induction time;
- Mechanical properties measured as e-modulus and elongation at break;
- Slow crack growth resistance measured with CTL at 60 C;
- Structural build up measured with rheology
- MFR5, MFR21 and FRR21/5
- We see no reason why MDPE PE80 or HDPE PE100 can't be used as media pipes for hydrogen transport.

We have also found that:

- There is no adverse effect if the pipes have previously been used for natural gas transport, still no effect on the above-mentioned properties;
- The pipes that have been exposed to 20 years of usage as natural gas transport pipes show the same properties as unused pipes in the above-mentioned properties;
- Pipes with a total of 24 years of usage, natural gas transport + hydrogen transport show the same properties as virgin pipes.

Discussion:

All the results in this report points in one direction that neither hydrogen gas transport or a prior use of the pipes for natural gas transport results in any negative effect on the properties of the pipes.

However if one wants to make a more detailed judgement of the remaining life of the pipe one should perform pressure testing at 80 C 3,9 MPa and 3,5 MPa for the PE80 pipes. Then one can use the Ke extrapolation factor from ISO 9080 and if the pipes survive 4380 h this would indicate a remaining life time of 50 years and if the pipes survive 8760 h it would indicate a remaining life time of 100 years. Of course this is not taking environmental factors like acidity of the soil, chemical contaminants, rock impingements etc but it will provide a further insight to the remaining life of the pipes under good conditions. A suggestion would be to test the pipes that have prior to the hydrogen transport been used for 20 year in the natural gas grid as these represent the worst case scenario.

For the PE100 pipes the same procedure would apply but because of the high stress resistance 4,8 MPa and 4,5 MPa at 80 C would be applicable.

A study of the SEM curves for each material can be prudent, before selecting the final stress levels to which they should test to determine the remaining lifetime.

Reference list:

1. Rheological characterisation of Polyethylene fractions – Heino E-L, Lehtinen A, Tanner J, Seppälä J, Theor. Applied Rheology Proceedings, Int. Congr of Rheology, 11'th (1992), 1, 360-362
2. The influence of molecular structure on some rheological properties of PE, Heino E-L, Annual transactions of the Nordic rheological society, 1995
3. EN1555 Plastics piping systems for the supply of gaseous fuels-Polyethylene(PE)- Part 1 General, December 2002

APPENDIX 2: FORCE final report

Indledning

FORCE Technology fik mulighed for at deltage i et DGC projekt om den mulige brug af danske naturgasrør til distribution af brint (se brev fra DGC til FORCE Technology, dateret 20. april 2006).

En af de oprindelige deltagere trak sig fra projektet. Den oprindelige plan var at se på brints mulige indflydelse på stål under statisk tryk. DGC blev gjort opmærksom på, at det oprindelige koncept måske var mindre vigtigt og i kontakten til FORCE Technology blev der lagt vægt på, at projektet skulle fokusere på det dynamiske aspekt, dvs. udmattelse grundet varierende indre tryk.

Da FORCE Technology blev involveret, var der allerede igangværende undersøgelser som tilstræbte at beskrive udmattelsesgrænserne i brugen af de eksisterende rør til distribution af brint. Disse undersøgelser var baseret på brudmekaniske principper og det blev fundet mindre nyttigt at prøve at reproducere dette arbejde. Det blev i stedet besluttet at foretage en række dynamiske fuldskala tests. Som forsøgsrør valgtes Ø 520 mm API x 70, der blevet taget ud af det eksisterende danske naturgasnet, pga. ændringer i rørføringen. Rørsamlingerne var udført med SMAW rundsømme. Svejsningernes kvalitet antages at være repræsentative for det danske ledningsnet. Forsøgsrørene skulle udsættes for 100 % brint under varierende indvendige tryk, hvor trykamplituden blev bestemt af den maksimale tilladte trykpulsation i naturgasledningerne. Når, og hvis, der blev konstateret revnevækst i rørene ved periodiske ultralydundersøgelser, skulle forsøget stoppes for opmåling af revnedybde og længde. Hvis der ikke forekom revnedannelse/vækst indenfor en forsøgsperiode på 15.000 trykvariationer (svarende til 1 trykvariation pr dag i 40 år), var muligheden enten at fortsætte i en længere periode eller øge trykamplituden.

Det var på forhånd erkendt, at et muligt svar på forsøget kunne blive, at ingen revner ville fremkomme inden for forsøgets løbetid. Et sådant resultat ville stadigvæk kunne give nogen tillid til de eksisterende rørlednings anvendelse til brintdistribution, forudsat selvfølgelig, at der ikke i praksis forekommer grovere svejsefejl end i forsøgsrørene.

Det blev også på forhånd påpeget, at forsøg udført med så stor trykamplitude, at det ville resultere i dannelse af udmattelsesrevner i røret, uanset om der er brint tilstede eller ej, ikke tjener noget formål, med hensyn til at karakterisere den mulige skadelige indflydelse af brint.

På den anden side, hvis revnedannelse kunne fremprovokeres inden for de normalt tilladelige trykvariationer i dette forsøgsprogram, ville det kunne give værdifulde sammenligningsgrundlag for igangværende brudmekaniske forsøg andre steder.

Overblik over forsøget

Forsøgsmateriale:	Ø 520 mm x 7 mm, API 5L x 70
Undersøgelse før forsøg:	100 % ultralydsundersøgelse fra ydersiden
Undersøgelse efter forsøg:	100 % ultralydsundersøgelse fra ydersiden 100 % MPI fra indersiden Metallografisk undersøgelse
Tryk under forsøget:	Første forsøg 60 bar \pm 10 bar Andet forsøg 55 bar \pm 15 bar
Frekvens:	0,002 Hz ~ 8.33 min/cycle. Dette blev valgt for at holde frekvensen på det niveau, som er normalt for slow strain rate testing.

Antal trykændringer pr. forsøg: 15000, svarende til et trykudsving om dagen i 40 år.

Undersøgelse under testen: 100 % ultralyd fra ydersiden

Hvis utætheder forekommer stoppes forsøget. Et nyt forsøg igangsættes ved lavere maksimum belastning og/eller lavere trykudsving.

Hvis der konstateres beskeden revnevækst, fortsætter forsøget en ekstra periode eller indtil utæthed.

Hvis der ingen revner findes, fortsætter forsøget, men med en smule højere trykudsving.

Det blev på forhånd bestemt ikke at bruge trykudstrækninger/udsving højere end + 15 bar, da det ville øge risikoen for begyndende udmattelsesrevner, uanset det indre miljø.

Når forsøget er blevet stoppet bliver det mulige revneområde analyseret grundigt, således at revnedybden måles, en mulig revnevækstrate bestemmes til brug for fremtidige sammenligninger med brudmekaniske forsøgsresultater. Hvis der ikke forefindes revner, tjekkes hele svejsesømmen vha. MPI, og mikro prøver udvælges til at beskrive svejseområdet.

Testrørets længde


Da testrøret skal simulere en i princippet uendelig lang gasledning, nedgravet i jord, er det vigtigt at spændingerne i testrørets rundgående svejsning ikke påvirkes af spændinger fra forstærkningsringene. Dette hensyn nødvendiggør testrør af en vis længde. Omvendt er det en fordel at benytte korte testrør for at minimere den brintmængde, der skal bruges for at tryksætte testrøret under hver cyklus.

Vi har derfor beregnet de rundgående spændinger i testrøret som funktion af afstanden fra en forstærkningsring. Resultatet af beregningerne er vist på figur 1. Som det ses er de rundgående spændinger i røret upåvirket af forstærkningsringen i afstande over 200 mm fra forstærkningsringen. I afstande mellem ca. 90 mm og 200 mm fra forstærkningsringen, vil de rundgående spændinger være en anelse større end langt fra forstærkningsringen.


Der blev valgt en totallængde på testrøret på 340 mm og en afstand mellem de rundgående forstærkningsringe på 200 mm. Det betyder, at de rundgående spændinger ved svejsningen i testrøret vil være som i en afstand på 100 fra forstærkningsringene, jf. figur 2.

Med denne geometri af testrøret opnås en anelse konservative resultater og brintforbruget minimeres.

Forstærkningsringene blev påsat for at eliminere bøjespændinger i svejsningen mellem testrør og inder-rør.




Figur 1 De rundgående spændinger som funktion af afstanden fra forstærkningsringen.



Figur 2 Afstanden mellem de udvendige forstærkningsringe er 200 mm.

Testopstillingen

Opstillingen til den pulserende tryksætning af røret er vist på nedenstående skitse, figur 3.



Ventil 1 og 5 er drøvleventiler

Ventil 2 og 4 er motorventiler (trykluft eller solenoid)

3 er kontakt-manometer, der styrer motorventilerne

Ved et tryk på >70 bar skal ventil 4 lukke og ventil 2 åbne

Ved tryk <50 bar skal ventil 2 lukke og ventil 4 åbne

Ventil 6 er lukket hele tiden

Ventil 5 skal indstilles så trykstigningen fra 50 til 70 bar sker på ca. 8 min.

Ventil 1 kan indstilles så tryktabet fra 70 til 50 bar strækker sig over 2 til 5 sekunder

Figur 3 Principskitse af testopstillingen

Signalerne fra tryktransduceren føres til en computer/datalogger, der registrerer trykvariationerne i testrøret.

Trykket inde i testrøret varieres mellem et maksimums- og et minimumstryk, som forudindstilles på kontaktmanometeret (3). Kontaktmanometeret indstilles efter tryktransducerens visning og ikke efter kontaktmanometerets skalavisning. Kontaktmanometeret styrer åbning/lukning af ventilerne 2 og 4.

Trykstignings- og tryksænkningshastighederne reguleres med drøvleventilerne 1 og 5. Foto nr. 1 og 2 viser testopstillingen i sin helhed og i detaljer.

Trykstigningen- og sænkningen kan også foretages manuelt med kontakterne vist på foto nr. 3. Bemærk at der bag glasset på kontaktboksen sidder en tæller, der registrerer antallet af trykcykler. Tælleren er kun tænkt som back-up.

Systemet tilsluttes en brintforsyning, der leverer brinten ved et tryk på ca. 90 bar. Trykket skal under alle omstændigheder være højere end maksimaltrykket under forsøget.

Inden der tilsluttes brint, skylles hele systemet, inkl. fødeledningen til brint, igennem med kvælstof for at fjerne ilt fra systemet.

En flaske med kvælstof tilsluttes fødeledningen og trykket hæves ved manuel betjening til 10-20 bar, hvorefter systemet aflastes til 1 bar. Proceduren gentages 2-3 gange.

Når ilten således er skyllet (fortyndet) ud af systemet, tilsluttes brinten og forsøget kan starte med omskifteren i AUTO (se foto nr. 3).

Under forsøget registreres trykket med transduceren (MBS 4701/3011/1AB08) og et program i Labview registrerer antallet af cykler.

Samme program giver signal, hvis ventil 2 er åben i mere end 5 minutter, eller hvis ventil 4 er åben i mere end 15 minutter. Hvis ovennævnte åbningstider overskrides, lukkes for brinttilførslen og årsagen til de lange åbningstider undersøges.



Foto nr. 1




Foto nr. 2




Foto nr. 3

Forsøgsgang

Til brug for forsøget var følgende rørnumre/svejsesømsnumre til rådighed.

Rørnummer	Svejsesømnummer	Testrør nummer
42089/41391	23-36	1
42083/42089	23-35	2
41420/4286	23-32	3
42086/4276	23-33	
41391/41392	23-37	

Der blev fremstillet 3 testemner, som anført i ovennævnte tabel.

Til det første forsøg (testrør nr. 1) blev det valgt at gennemføre forsøget med en trykvariation mellem 50 og 70 bar. 70 bar er det maksimale gastryk, der haves i det danske naturgasnet.

Inden starten af udmattelsestesten blev den rundgående svejsesøm i testrøret undersøgt med ultralyd (alle ultralyd-rapporterne er givet i bilag 1).

Figur 4 viser trykstignings- og aflastningstider for de enkelte cykler. Som det ses er der benyttet trykstignings- og aflastningstider på den konservative side.

Figur 5 viser max/min-trykket gennem de 15.000 cykler, hvortil forsøget er planlagt.

Efter 15.000 trykvariationer blev rundsømmen i testrør nr. 1 atter undersøgt med ultralyd (se bilag 1). Der blev ikke konstateret nogen ændringer i forhold til ultralydundersøgelsen inden forsøgsstart. Det vil sige, at der under forsøget ikke er initieret og vokset revner af detekterbar størrelse.

I stedet for at fortsætte forsøget med endnu 15.000 cykler, blev det besluttet at starte testrør nr. 2 med en 50 % højere spændingsvariation.

Da det maksimale tryk i naturgassystemet næppe vil overstige 70 bar, blev trykvariationen udvidet nedad, således at forsøg nr. 2 blev gennemført med trykvariationer mellem 40 og 70 bar.

Figur 6 viser trykstignings- og trykaflastningstiderne for de enkelte cykler under forsøg nr. 2.

Figur 7 viser max/min-trykket gennem de første 15.000 cykler af forsøg nr. 2.

Efter 15.000 cykler blev forsøget stoppet og rundsømmen blev underkastet en fornyet ultralydundersøgelse. Heller ikke i dette tilfælde kunne der konstateres initiering og vækst af udmattelsesrevner.


I stedet for at starte et 3. forsøg med en endnu større trykvariation, blev det besluttet at fortsætte forsøg nr. 2 i yderligere 15.000 tryk cykler.

En af grundene til, at det blev valgt ikke at forøge trykvariationen var, at der skønnedes at være en rimelig sandsynlighed for, at udmattelsesrevner ville initiere, uanset om der var brint til stede eller ej. Da det er brintens eventuelle fremmende virkning på initieringen og vækst af udmattelsesrevner, der ønskes belyst, har et forsøg, der under alle omstændigheder fører til revnedannelse, ingen mening.


Figur 8 viser max/min- trykket gennem de sidste 15.000 cykler af forsøg nr. 2.

Efter i alt 30.000 trykvariationer mellem 40 og 70 bar, blev forsøg nr. 2 stoppet og rundsømmen blev igen undersøgt med ultralyd.


Igen blev det konstateret, at der ikke fandtes spor efter initiering og vækst af udmattelsesrevner. Det blev derfor besluttet at underkaste testrør nr. 2 en nærmere laboratorieundersøgelse.




Figur 4 Trykstigningen og trykafastningen mellem 50 og 70 bar.




Figur 5 Maksimum og minimum tryk gennem forsøg 1.



Figur 6 Trykstigningen og trykafloadningen mellem 40 og 70 bar.



Figur 7 Maksimum og minimum tryk gennem de første 15.000 cykler af forsøg nr. 2.



Figur 8 Maksimum og minimumtryk gennem de sidste 15.000 cykler af forsøg 2.

Laboratorieundersøgelse – Testrør nr. 2

Testrør nr. 2 blev skåret af på længden lige inden for forstærkningsringene og derefter skåret igennem langsgående. Det således åbnede rør er vist på foto nr. 4.

En visuel og stereomikroskopisk undersøgelse afslørede ingen revner, hvorfor de indvendige røroverflader blev underkastet en magnetpartikel inspektion (MPI) med fluorescerende magnetpulver. Heller ikke denne undersøgelsesmetode kunne entydigt afsløre revner. En af de tydeligste indikationer er markeret med en pil på foto nr. 5.

Et snit vinkelret på svejsningen og gennem indikationen, markeret med en pil på foto nr. 5 blev skåret ud og præpareret til mikrostrukturundersøgelse.

Det præparerede snit er vist på foto nr. 6. Overgangene mellem svejsesømme og grundmaterialet, både på inder- og ydersiden, er vist i større forstørrelse på foto nr. 7, 8, 9 og 10. Det er netop i overgangene mellem svejsemetal og grundmateriale, at udmattelsesrevner forventes at initiere og hvis brint har en accelererende effekt, er det ved de indvendige overgange. Som det fremgår af fotografierne ses der ikke antydning af revneinitiering.

Som det ses af foto nr. 8 er det en kileformet spalte mellem gennemløbet af svejsemetal og grundmaterialet, der har givet anledning til MPI-indikationerne.

Der er absolut ikke tegn på revneinitiering i bunden af den kileformede spalte, og det er netop her, eventuelle udmattelsesrevner ville have startet.



Foto nr. 4 Testrør nr. 2 efter testen.




Foto nr. 5 Testrør nr. 2. Under magnetpulverprøvningen. Den tydeligste indikation er markeret med en pil.




Foto nr. 6 Snittet gennem svejsningen




Foto nr. 7 Inderside til venstre




Foto nr. 8 Underside til højre




Foto nr. 9 Underside til venstre




Foto nr. 10 Yderside til højre

Konklusion

Testrør nr. 1 og 2 er blevet udsat for hhv. 15.000 pulsationer mellem 50 og 70 bar og 30.000 pulsationer mellem 40 og 70 bar. Der er ikke initieret udmattelsesrevner i disse forsøg.

De rundgående svejsninger er oprindeligt undersøgt med ultralyd og fundet acceptable i henhold til de håndværksmæssige godkendelseskriterier, beskrevet i API 1104. Disse kriterier repræsenterer en svejskvalitet, som en god svejser skal kunne opnå rutinemæssigt.

De benyttede svejsninger er valgt tilfældigt og ikke ud fra, at de skulle indeholde bestemte fejltyper og – størrelser. De repræsenterer således typiske svejsninger fra det danske naturgasnet.

Testrør 1 før start

Markrapport/Ultralyd svejsesømme

Division for Inspektion og Prøvning



DANAK Reg. nr.	Bilag nr.	FORCE id/FORCE sag nr. 107-26158.10		Rapport nr. U 01	Side af 1 af 1
Rekvirition nr.	Kontrolperiode/Dato 11-10-07	Tekniker (Init.) NT	Certifikat nr. 0302-U-N3	Assistent (Init.)	Certifikat nr.
Rekvirent DGC/FORCE (Brint-projekt)			Entreprenør -		
Bygherre -			Kontrolsted FORCE Technology, Brøndby		
Emne (Mrk., dim., antal) Testrør med rundsøm udtaget fra ledningsnet, dim. 519 mm Ø, t = 7 mm.			Tegning nr./Revision		
			Modtagedato		
			Materialebetegnelse		
Supplerende oplysninger (uden ansvar, se nedenfor)					
Fugeform <input type="checkbox"/> X <input type="checkbox"/> Y <input type="checkbox"/> U <input checked="" type="checkbox"/> V <input type="checkbox"/> K <input type="checkbox"/> I		Andet		Tidspunkt for undersøg. Timer efter sv.	Varmebehandling <input type="checkbox"/> Ja <input type="checkbox"/> Nej
Svejsemetode 121 131 135 136 141 <input type="checkbox"/> Ma.lysbue 111 <input type="checkbox"/> Pulversv. <input type="checkbox"/> MIG <input type="checkbox"/> MAG <input type="checkbox"/> Fluxfyldt tr. <input type="checkbox"/> TIG		Andet		Backing <input type="checkbox"/> Bagsk. mm	
Overflade af svejsning <input type="checkbox"/> Slebet <input checked="" type="checkbox"/> Jævn <input type="checkbox"/> Grov		Overvulst <input checked="" type="checkbox"/> Som svejst <input type="checkbox"/> Slebet		Andet	
Undersøgelingsprocedure/klasse <input checked="" type="checkbox"/> EN 1714, niveau B <input type="checkbox"/> ASME V <input type="checkbox"/> IIW 527-76 <input type="checkbox"/> ADM-HP 5/3, Klasse		Andet		Apparat Reg. nr. UL WD 6	
Apparattype <input type="checkbox"/> USN 52 <input type="checkbox"/> USK 7 D <input type="checkbox"/> USK 7 <input type="checkbox"/> EPOCH III <input checked="" type="checkbox"/> EPOCH XT		Andet			
Normalhoved		Vinkelhoved			
Type	A: MSEB 4 B:	Type	C: MWB 70e D:	E:	
Reg. nr. / Frekvens	UAR53 / 4 MHz / MHz	Reg. nr. / Sand vinkel	203 / 69°	° / °	
Følsomhedsindstilling		Følsomhedsindstilling			
Grundinds. ~ ref. kurve	42 dB	Grundinds. ~ ref. kurve	59 dB	dB	
Overføringskorrektion	0 dB	Overføringskorrektion	0 dB	dB	
Afsøgningstillæg	6 dB	Afsøgningstillæg	12 dB	dB	
Sum	48 dB	Sum	71 dB	dB	
DAC: Hul ø = 3 mm, Skallængde = 100 mm		DGS (AVG): Skive ø = mm, Skallængde = mm			
<input type="checkbox"/> V1-Reg. nr. <input checked="" type="checkbox"/> V2-Reg. nr.		<input checked="" type="checkbox"/> TIF-blok Reg. nr. 33			
Lydhoved kontrol <input checked="" type="checkbox"/> Operatørkontrol af lydhoveder udført		Koblingsmiddel <input checked="" type="checkbox"/> Gel <input type="checkbox"/> Tapetklister <input type="checkbox"/> Olie <input type="checkbox"/> Vand			
Kvalitetskrav <input type="checkbox"/> EN 1712, level <input type="checkbox"/> DS 412, søm kl. <input type="checkbox"/> ASME VIII.1 <input type="checkbox"/> ADM-HP 5/3 <input checked="" type="checkbox"/> Alt over -18 dB registreres		Andet			
Scanning for længdefejl og lagdeling		Scanning for tværfejl			
Position 1 2 3 4 5 6 7 8 9 10 Hoved C C A A		Position 11 12 13 14 15 16 Hoved C C C C			
Undersøgelses omfang					
Svejsesømmen undersøges 100% for langs- og tværgående fejl. Ref. = ekko fra 3 mm hul i 10 mm dybde. Ingen DAC.					
Alt over -18 dB registreres.					
Undersøgelses resultat					
Enkelte indikationer over -18 dB, se vedl. skitse.					
Indikationerne vurderes at stamme fra gennemløb.					
Rep. opmærkning <input type="checkbox"/> På emne <input type="checkbox"/> På skitse		Kontrol af opslibning <input type="checkbox"/> Kontrol af reparation <input type="checkbox"/> Stempel		Bilag vedlagt <input checked="" type="checkbox"/> 1 stk.	
Att. af rekvirent <input type="checkbox"/> Kopi afleveret til:		Att. af bygherre/Tilsyn <input type="checkbox"/> Kopi afleveret til:		Tekniker (Dato/Underskrift) 11-10-07, Norman Thomsen	
Dato/Underskrift		Dato/Underskrift		Dato/Underskrift	

Supplerende oplysninger : Oplysningerne i de grå felter er til information og angives kun i den udstrækning, de er tilgængelige og relevante. Deres angivelse på nærværende markrapport kan ikke betragtes som en verifikation af deres rigtighed.

Testrør 1 efter 15.000 cycles

Markrapport/Ultralyd svejsesømme




Division for Inspektion og Prøvning

DANAK Reg. nr.	Bilag nr.	FORCE id/FORCE sag nr. 107-26158.10		Rapport nr. U 03	Side af 1 af 1
Rekvistion nr.	Kontrolperiode/Dato 30-6-08	Tekniker (Init.) NT	Certifikat nr. 0302-U-N3	Assistent (Init.)	Certifikat nr.
Rekvirent DGC/FORCE (Brint-projekt)			Entrepreneur		
Bygherre			Kontrolsted FORCE Technology, Brøndby		
Emne (Mrk., dim., antal) Testrør med rundsøm udtaget fra ledningsnet, dim. 519 mm Ø, t = 7 mm.				Tegning nr./Revision	
Samme rør som UT-01, efter en periode i drift (15000 cycles)				Modtagedato	
Supplerende oplysninger (uden ansvar, se nedenfor)					
Fugeform <input type="checkbox"/> X <input type="checkbox"/> Y <input type="checkbox"/> U <input checked="" type="checkbox"/> V <input type="checkbox"/> K <input type="checkbox"/> I		Andet		Tidspunkt for undersøg. Timer efter sv.	Varmebehandling <input type="checkbox"/> Ja <input type="checkbox"/> Nej
Svejsemetode 121 131 135 136 141 <input type="checkbox"/> Ma.lysbue 111 <input type="checkbox"/> Pulversv. <input type="checkbox"/> MIG <input type="checkbox"/> MAG <input type="checkbox"/> Fluxfyldt tr. <input type="checkbox"/> TIG		Andet		Basking <input type="checkbox"/> Bask. mm	
Overflade af svejsning <input type="checkbox"/> Slebet <input checked="" type="checkbox"/> Jævn <input type="checkbox"/> Grov		Overvulst <input checked="" type="checkbox"/> Som svejst <input type="checkbox"/> Slebet		Andet	
Undersøgelingsprocedure/klasse <input checked="" type="checkbox"/> EN 1714, niveau B <input type="checkbox"/> ASME V <input type="checkbox"/> IIW 527-76 <input type="checkbox"/> ADM-HP 5/3, Klasse		Apparattype <input type="checkbox"/> USN 52 <input type="checkbox"/> USK 7 D <input type="checkbox"/> USK 7 <input type="checkbox"/> EPOCH III <input checked="" type="checkbox"/> EPOCH XT		Apparat Reg. nr. UL WD 6	
Normalhoved		Vinkelhoved			
Type	A: B:	Type	C: MWB 70e	D:	E:
Reg. nr. / Frekvens	/ MHz	Reg. nr. / Sand vinkel	203 / 69 °	/ °	/ °
Følsomhedsindstilling		Følsomhedsindstilling			
Grundinds. ~ ref. kurve	dB	Grundinds. ~ ref. kurve	52 dB	dB	dB
Overføringskorrektion	dB	Overføringskorrektion	0 dB	dB	dB
Afsøgningstillæg	dB	Afsøgningstillæg	12 dB	dB	dB
Sum	dB	Sum	64 dB	dB	dB
DAC: Hul ø = 3 mm, Skallalængde = 100 mm		DGS (AVG): Skive ø = mm, Skallalængde = mm			
<input type="checkbox"/> V1-Reg. nr. <input checked="" type="checkbox"/> V2-Reg. nr.		<input checked="" type="checkbox"/> TIF-blok Reg. nr. 33			
Lydhoved kontrol <input checked="" type="checkbox"/> Operatørkontrol af lydhoveder udført		Koblingsmiddel <input checked="" type="checkbox"/> Gel <input type="checkbox"/> Tapetklister <input type="checkbox"/> Olie <input type="checkbox"/> Vand <input type="checkbox"/> Andet			
Kvalitetskrav <input type="checkbox"/> EN 1712, level <input type="checkbox"/> DS 412, søm kl. <input type="checkbox"/> ASME VIII.1 <input type="checkbox"/> ADM-HP 5/3		Andet <input checked="" type="checkbox"/> Alt over -12 dB registreres			
Scanning for længdefejl og lagdeling		Scanning for tværfejl			
Position 1 2 3 4 5 6 7 8 9 10		Position 11 12 13 14 15 16			
Hoved C C		Hoved C C C C C C			
Undersøgelses omfang					
Svejseømmen undersøges 100% for langs- og tværgående fejl. Ref. = ekko fra 3 mm hul i 10 mm dybde. Ingen DAC.					
Alt over -18 dB registreres.					
Undersøgelses resultat					
Der konstateredes ingen ændringer i forhold til resultatet i rapport U-01.					
Rep. opmærkning <input type="checkbox"/> På emne <input type="checkbox"/> På skitse		Kontrol af opslibning <input type="checkbox"/> Kontrol af reparation <input type="checkbox"/> Stempel		Bilag vedlagt <input type="checkbox"/> stk.	
Att. af rekvirent <input type="checkbox"/> Kopi afleveret til:		Att. af bygherre/Tilsyn <input type="checkbox"/> Kopi afleveret til:		Tekniker (Dato/Underskrift) 30-6-08, Norman Thomsen	
Dato/Underskrift		Dato/Underskrift		Dato/Underskrift	

Supplerende oplysninger : Oplysningerne i de grå felter er til information og angives kun i den udstrækning, de er tilgængelige og relevante. Deres angivelse på nærværende markrapport kan ikke betragtes som en verifikation af deres rigtighed.

Testværl til H₂: 1 rundspæn, t = 7 mm.
 Registrering af UT-indikationer.

1630



↓↑ = Lydretning

Indikationer kun fra viste retninger.
 Vurderes som gennemløb.
 107-26158.10. NT 11/10-07.

Testrør 2 før start

Markrapport/Ultralyd svejsesømme



Division for Inspektion og Prøvning

DANAK Reg. nr.	Bilag nr.	FORCE id/FORCE sag nr. 107-26158.10		Rapport nr. U 02	Side af 1 af 1
Rekvirering nr.	Kontrolperiode/Dato 9-6-2008	Tekniker (Init.) NT	Certifikat nr. 0302-U-N3	Assistent (Init.)	Certifikat nr.
Rekvirent DGC/FORCE (Brint-projekt)			Entrepreneur -		
Bygherre -			Kontrolsted FORCE Technology, Brøndby		
Emne (Mrk., dim., antal) Testrør med rundsøm udtaget fra ledningsnet, dim. 519 mm Ø, t = 7 mm.				Tegning nr./Revision	
Mærket rør 2. t målt til 7,4mm				Modtagedato	
Materialebetegnelse					
Supplerende oplysninger (uden ansvar, se nedenfor)					
Fugeform <input type="checkbox"/> X <input type="checkbox"/> Y <input type="checkbox"/> U <input checked="" type="checkbox"/> V <input type="checkbox"/> K <input type="checkbox"/> I <input type="checkbox"/> Andet		Tidspunkt for undersøg. Timer efter sv.		Varmebehandling <input type="checkbox"/> Ja <input type="checkbox"/> Nej <input type="checkbox"/> Basking mm	
Svejsemetode <input type="checkbox"/> Ma.lysbue 111 <input type="checkbox"/> Pulversv. <input type="checkbox"/> MIG <input type="checkbox"/> MAG <input type="checkbox"/> Fluxfyldt tr. <input type="checkbox"/> TIG		121 131 135 136 141		Andet	
Overflade af svejsning <input type="checkbox"/> Slebet <input checked="" type="checkbox"/> Jævn <input type="checkbox"/> Grov		Overvulst <input checked="" type="checkbox"/> Som svejst <input type="checkbox"/> Slebet		Andet	
Undersøgelsesprocedure/klasse <input checked="" type="checkbox"/> EN 1714, niveau B <input type="checkbox"/> ASME V <input type="checkbox"/> IIW 527-76 <input type="checkbox"/> ADM-HP 5/3, Klasse		Apparattype <input type="checkbox"/> USN 52 <input type="checkbox"/> USK 7 D <input type="checkbox"/> USK 7 <input type="checkbox"/> EPOCH III <input checked="" type="checkbox"/> EPOCH XT		Apparat Reg. nr. UL WD 6	
Normalhoved Type A: MSEB 4 B: /		Vinkelhoved Type C: MWB 70e D: / E: /			
Reg. nr. / Frekvens UAR53 / 4 MHz / MHz		Reg. nr. / Sand vinkel 203 / 69 ° / ° / °			
Følsomhedsindstilling Grundinds. ~ ref. kurve 42 dB dB		Følsomhedsindstilling Grundinds. ~ ref. kurve 49 dB dB dB			
Overføringskorrektion 0 dB dB		Overføringskorrektion 0 dB dB dB			
Afsøgningstillæg 6 dB dB		Afsøgningstillæg 18 dB dB dB			
Sum 48 dB dB		Sum 67 dB dB dB			
DAC: Hul ø = 3 mm, Skalalængde = 100 mm		DGS (AVG): Skive ø = mm, Skalalængde = mm			
<input type="checkbox"/> V1-Reg. nr. <input checked="" type="checkbox"/> V2-Reg. nr. <input checked="" type="checkbox"/> TIF-blok Reg. nr. 33		Andet			
Lydhoved kontrol <input checked="" type="checkbox"/> Operatørkontrol af lydhoveder udført		Koblingsmiddel <input checked="" type="checkbox"/> Gel <input type="checkbox"/> Tapetklister <input type="checkbox"/> Olie <input type="checkbox"/> Vand <input type="checkbox"/> Andet			
Kvalitetskrav <input checked="" type="checkbox"/> EN 1712, level <input type="checkbox"/> DS 412, søm kl. <input type="checkbox"/> ASME VIII.1 <input type="checkbox"/> ADM-HP 5/3 <input checked="" type="checkbox"/> Alt over -18 dB registreres		Andet			
Scanning for længdefejl og lagdeling		Scanning for tværfejl			
Position 1 2 3 4 5 6 7 8 9 10		Position 11 12 13 14 15 16			
Hoved C C A A		Hoved C C C C			
Undersøgelses omfang					
Svejsesømmen undersøgtes 100% for langs- og tværgående fejl. Ref. = ekko fra 3 mm hul i 10 mm dybde. Ingen DAC.					
Alt over -18 dB registreres.					
Undersøgelses resultat					
Enkelte indikationer over -18 dB, se vedl. skitse.					
Indikationerne vurderes at stamme fra gennemløb.					
Rep. opmærkning <input type="checkbox"/> På emne <input type="checkbox"/> På skitse		Kontrol af opslibning <input type="checkbox"/> Kontrol af reparation <input type="checkbox"/> Stempel		Bilag vedlagt <input checked="" type="checkbox"/> 1 stk.	
Tekniker (Dato/Underskrift) Norman Thomsen 9-6-2008, Norman Thomsen		Att. af myndighed <input type="checkbox"/> Kopi afleveret til:			
Att. af rekvirent <input type="checkbox"/> Kopi afleveret til:		Att. af bygherre/Tilsyn <input type="checkbox"/> Kopi afleveret til:		Dato/Underskrift	

Supplerende oplysninger : Oplysningerne i de grå felter er til information og angives kun i den udstrækning, de er tilgængelige og relevante. Deres angivelse på nærværende markrapport kan ikke betragtes som en verifikation af deres rigtighed.

Testrør 2 Efter 15.000 cycles

Markrapport/Ultralyd svejsesømme

Division for Inspektion og Prøvning

DANAK Reg. nr.	Bilag nr.	FORCE Id/FORCE sag nr. 107-26158.10		Rapport nr. U 04	Side af 1 af 1
Rekvistion nr.	Kontrolperiode/Dato 5-1-2009	Tekniker (Init.) NT	Certifikat nr. 0302-U-N3	Assistent (Init.)	Certifikat nr.
Rekvirent DGC/FORCE (Brint-projekt)			Entreprenør -		
Bygherre -			Kontrolsted FORCE Technology, Brøndby		
Emne (Mrk., dim., antal) Testrør med rundsøm udtaget fra ledningsnet, dim. 519 mm Ø, t = 7 mm.			Tegning nr./Revision		
Mærket rør 2. t målt til 7,4mm			Modtagedato		
Materialebetegnelse					
Supplerende oplysninger (uden ansvar, se nedenfor)					
Fugeform <input type="checkbox"/> X <input type="checkbox"/> Y <input type="checkbox"/> U <input checked="" type="checkbox"/> V <input type="checkbox"/> K <input type="checkbox"/> I		Andet		Tidspunkt for undersøg. Timer efter sv.	Varmebehandling <input type="checkbox"/> Ja <input type="checkbox"/> Nej
Svejsemetode <input type="checkbox"/> Ma.lysbue 111 <input type="checkbox"/> Pulversv. <input type="checkbox"/> MIG <input type="checkbox"/> MAG <input type="checkbox"/> Fluxfyldt tr. <input type="checkbox"/> TIG		Andet		Backing <input type="checkbox"/> Bagsk. mm	
Overflade af svejsning <input type="checkbox"/> Slebet <input checked="" type="checkbox"/> Jævn <input type="checkbox"/> Grov		Overvulst <input checked="" type="checkbox"/> Som svejst <input type="checkbox"/> Slebet		Andet	
Undersøglesprocedure/klasse <input checked="" type="checkbox"/> EN 1714, niveau B <input type="checkbox"/> ASME V <input type="checkbox"/> IIW 527-76 <input type="checkbox"/> ADM-HP 5/3, Klasse		Apparattype <input type="checkbox"/> USN 52 <input type="checkbox"/> USK 7 D <input type="checkbox"/> USK 7 <input type="checkbox"/> EPOCH III <input checked="" type="checkbox"/> EPOCH XT		Apparat Reg. nr. UL WD 6	
Normalhoved		Vinkelhoved			
Type	A:	B:	Type	C: MWB 70e	D: E:
Reg. nr. / Frekvens	/ MHz	/ MHz	Reg. nr. / Sand vinkel	203 / 69 °	/ ° / °
Følsomhedsindstilling		Følsomhedsindstilling			
Grundinds. ~ ref. kurve	dB	dB	Grundinds. ~ ref. kurve	48 dB	dB
Overføringskorrektur	dB	dB	Overføringskorrektur	0 dB	dB
Afsøgningstillæg	dB	dB	Afsøgningstillæg	18 dB	dB
Sum	dB	dB	Sum	66 dB	dB
DAC: Hul ø = 3 mm, Skalalængde = 100 mm		DGS (AVG): Skive ø = mm, Skalalængde = mm			
V1-Reg. nr.		V2-Reg. nr.		TIF-blok Reg. nr. 33	
Lydhoved kontrol		Koblingsmiddel		Andet	
<input checked="" type="checkbox"/> Operator kontrol af lydhoveder udført		<input checked="" type="checkbox"/> Gel <input type="checkbox"/> Tapetklister <input type="checkbox"/> Olie <input type="checkbox"/> Vand		<input type="checkbox"/> Andet	
Kvalitetskrav		Andet			
<input type="checkbox"/> EN 1712, level <input type="checkbox"/> DS 412, søm kl. <input type="checkbox"/> ASME VIII.1 <input type="checkbox"/> ADM-HP 5/3		<input checked="" type="checkbox"/> Alt over -12 dB registreres			
Scanning for længdefejl og lagdeling		Scanning for tværfejl			
Position 1 2 3 4 5 6 7 8 9 10		Position 11 12 13 14 15 16			
Hoved C C A A		Hoved C C C C			
Undersøgelsens omfang					
Svejsesømmen undersøges 100% for langs- og tværgående fejl. Ref. = ekko fra 3 mm hul i 10 mm dybde. Ingen DAC.					
Alt over -12 dB registreres.					
Undersøgelsens resultat					
Enkelte indikationer over -12 dB, se vedl. skitse.					
Ingen ændringer i forhold til første undersøgelse					
Rep. opmærkning <input type="checkbox"/> På emne <input type="checkbox"/> På skitse		Kontrol af opslibning <input type="checkbox"/> Kontrol af reparation <input type="checkbox"/> Stempel		Bilag vedlagt <input type="checkbox"/> stk.	
Att. af rekvirent <input type="checkbox"/> Kopi afleveret til:		Att. af bygherre/Tilsyn <input type="checkbox"/> Kopi afleveret til:		Tekniker (Dato/Underskrift) Norman Thomsen 5-1-2009, Norman Thomsen	
Dato/Underskrift		Dato/Underskrift		Dato/Underskrift	

Testrør 2 after 30.000 cycles

Markrapport/Ultralyd svejsesømme

Division for Inspektion og Prøvning



DANAK Reg. nr.		Bilag nr.		FORCE id/FORCE sag nr. 107-26158.10		Rapport nr. U 05		Side af 1 af 1																																	
Rekvistion nr.		Kontrolperiode/Dato 7-9-2009		Tekniker (Init.) NT		Certifikat nr. 0302-U-N3		Assistent (Init.) 																																	
Rekvisitent DGC/FORCE (Brint-projekt)						Entreprenør -																																			
Bygherre -						Kontrolsted FORCE Technology, Brøndby																																			
Emne (Mrk., dim., antal) Testrør med rundsøm udtaget fra ledningsnet, dim. 519 mm Ø, t = 7 mm.						Tegning nr./Revision 																																			
Mærket rør 2. t målt til 7,4mm						Modtagedato 																																			
Supplerende oplysninger (uden ansvar, se nedenfor)						Materialebetegnelse 																																			
Fugeform <input type="checkbox"/> X <input type="checkbox"/> Y <input type="checkbox"/> U <input checked="" type="checkbox"/> V <input type="checkbox"/> K <input type="checkbox"/> I <input type="checkbox"/> Andet						Tidspunkt for undersøgelse Timer efter sv.		Varmebehandling <input type="checkbox"/> Ja <input type="checkbox"/> Nej <input type="checkbox"/> Basking <input type="checkbox"/> Bagsk.																																	
Svejsemetode <input type="checkbox"/> Ma.lysbue 111 <input type="checkbox"/> Pulversv. <input type="checkbox"/> MIG <input type="checkbox"/> MAG <input type="checkbox"/> Fluxfyldt tr. <input type="checkbox"/> TIG						Andet		Overvulst <input checked="" type="checkbox"/> Som svejst <input type="checkbox"/> Slebet																																	
Overflade af svejsning <input type="checkbox"/> Slebet <input checked="" type="checkbox"/> Jævn <input type="checkbox"/> Grov						Andet		Under søgelsesprocedure/klasse <input checked="" type="checkbox"/> EN 1714, niveau B <input type="checkbox"/> ASME V <input type="checkbox"/> IIW 527-76 <input type="checkbox"/> ADM-HP 5/3, Klasse																																	
Apparattype <input type="checkbox"/> USN 52 <input type="checkbox"/> USK 7 D <input type="checkbox"/> USK 7 <input type="checkbox"/> EPOCH III <input checked="" type="checkbox"/> EPOCH XT						Andet		Apparat Reg. nr. UL WD 6																																	
Normalhoved						Vinkelhoved																																			
Type		A:		B:		Type		C: MWB 70e																																	
Reg. nr. / Frekvens		/ MHz		/ MHz		Reg. nr. / Sand vinkel		203 / 69 °																																	
Følsomhedsindstilling Grundinds. ~ ref. kurve dB dB Overføringskorrektion dB dB Afsøgningstillæg dB dB Sum dB dB						Følsomhedsindstilling Grundinds. ~ ref. kurve 53 dB dB Overføringskorrektion 0 dB dB Afsøgningstillæg 18 dB dB Sum 61 dB dB																																			
DAC: Hul \varnothing = 3 mm, Skalalængde = 100 mm						DGS (AVG): Skive \varnothing = mm, Skalalængde = mm																																			
<input type="checkbox"/> V1-Reg. nr. <input checked="" type="checkbox"/> V2-Reg. nr. <input checked="" type="checkbox"/> TIF-blok Reg. nr. 33						Andet																																			
<input checked="" type="checkbox"/> Lydhoved kontrol <input checked="" type="checkbox"/> Operatørkontrol af lydhoveder udført						<input checked="" type="checkbox"/> Koblingsmiddel <input checked="" type="checkbox"/> Gel <input type="checkbox"/> Tapetklister <input type="checkbox"/> Olie <input type="checkbox"/> Vand <input type="checkbox"/> Andet																																			
Kvalitetskrav <input type="checkbox"/> EN 1712, level <input type="checkbox"/> DS 412, søm kl. <input type="checkbox"/> ASME VIII.1 <input type="checkbox"/> ADM-HP 5/3 <input checked="" type="checkbox"/> Alt over -12 dB registreres						Andet																																			
Scanning for længdefejl og lagdeling						Scanning for tværfejl																																			
Position Hoved <table border="1" style="width:100%; text-align: center;"> <tr> <td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td>9</td><td>10</td> </tr> <tr> <td>C</td><td>C</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td> </tr> </table>						1	2	3	4	5	6	7	8	9	10	C	C									Position Hoved <table border="1" style="width:100%; text-align: center;"> <tr> <td>11</td><td>12</td><td>13</td><td>14</td><td>15</td><td>16</td> </tr> <tr> <td></td><td></td><td>C</td><td>C</td><td>C</td><td>C</td> </tr> </table>				11	12	13	14	15	16			C	C	C	C
1	2	3	4	5	6	7	8	9	10																																
C	C																																								
11	12	13	14	15	16																																				
		C	C	C	C																																				
Undersøgelses omfang Svejsesømmen undersøgelse 100% for langs- og tværgående fejl. Ref. = ekko fra 3 mm hul i 10 mm dybde. Ingen DAC.						Alt over -12 dB registreres.																																			
Undersøgelses resultat Enkelte indikationer over -12 dB.						Ingen ændringer i forhold til første undersøgelse																																			
Rep. opmærkning <input type="checkbox"/> På emne <input type="checkbox"/> Kontrol af opslibning <input type="checkbox"/> På skitse <input type="checkbox"/> Kontrol af reparation <input type="checkbox"/> Stempel						Bilag vedlagt <input type="checkbox"/> stk.		Tekniker (Dato/Underskrift) Norman Thomsen 7-9-2009, Norman Thomsen																																	
Att. af rekvisitent <input type="checkbox"/> Kopi afleveret til:						Att. af bygherre/Tilsyn <input type="checkbox"/> Kopi afleveret til:		Att. af myndighed <input type="checkbox"/> Kopi afleveret til:																																	
Dato/Underskrift						Dato/Underskrift		Dato/Underskrift																																	
Supplerende oplysninger : Oplysningerne i de grå felter er til information og angives kun i den udstrækning, de er tilgængelige og relevante. Deres angivelse på nærværende markrapport kan ikke betragtes som en verifikation af deres rigtighed.																																									

registrering af UT indikationer

-11 dB
 $\lambda = 5$
 $v = 150$
 ↓

-12 dB
 $\lambda = 5$
 $v = 700$
 ↓

↑
 $v = 100$
 $\lambda = 5$
 -11 dB

↑
 $v = 1120$
 $\lambda = 5$
 -11 dB

↑
 $v = 1180$
 $\lambda = 5$
 -12 dB

↑
 $v = 1280$
 $\lambda = 5$
 -11 dB

Indikationer kun fra viste lydretninger ↑↓
 Alle vurderes som gennemløb

107-26158.10 Rap. U12

U 9/6
 Norman Thomsen
 EN 473 Level 3